



# Department of Transportation

## Office of Project Development

700 E Broadway Avenue

Pierre, South Dakota 57501-2586 605/773-3268

FAX: 605/773-2614

January 19, 2016

### ADDENDUM NO. 1

**RE: Item #7, January 20, 2016 Letting - NH 0012(190)212, NH 0083(83)205, PCN 04W9, 053U, Edmunds, Walworth County - Cold Milling Asphalt Concrete, Asphalt Concrete Resurfacing, & Pipe Repair**

#### TO WHOM IT MAY CONCERN:

The following addenda to the plans shall be inserted and made a part of your proposal for the referenced project.

**SPECIAL PROVISIONS:** NO CHANGE

**BID ITEM FILE:** NO CHANGE

#### **PROJECT Q&A FORUM:**

PEN AND INK CHANGE to Question and Answer #1: The following shall replace the answer posted to Question #1:

*The material to be used as Base Course, Salvaged Asphalt mix shall meet the gradation requirements of Section 884.2.D.3. This material may be screened on the project provided all oversized material is hauled and stockpiled at the US 83/212 Junction west of Gettysburg.*

*Please remove the third and fourth paragraphs of the HAUL AND STOCKPILE GRANULAR MATERIAL note on sheet 9*

Sincerely,

Sam Weisgram  
Engineering Supervisor

SW/cj

CC: John Forman, Pierre Region Engineer  
John Villbrandt, Mobridge Area Engineer