



Department of Transportation

Aberdeen Region Office

West Highway 12

PO Box 1767

Aberdeen, South Dakota 57402-1767 605/626-2244

FAX: 605/626-7875

July 11, 2019

ADDENDUM NO. 1

Re: **029 S-171, PCN i5NL**
Codington, Hamlin, Deuel & Brookings Counties
Concrete Pavement Repair

TO WHOM IT MAY CONCERN:

PROPOSAL: No Changes

PLANS: **Sheet 8**, under the heading MAINTENANCE OF TRAFFIC, delete the following paragraph:

Open excavations at repair area locations shall not be allowed to be left open overnight. The Contractor shall complete the placement of PCCP on the same day as the existing PCCP is removed.

and replace with the following 2 paragraph:

Open excavations at nonreinforced PCCP repair area locations shall not be allowed to be left open overnight. The Contractor shall complete the placement of nonreinforced PCCP on the same day as the existing PCCP is removed.

Open excavations at Continually Reinforced Concrete Pavement (CRCP) repair area locations shall not be allowed to be left open more than 36 hours. In no case shall a repair area be left open over a holiday or weekend. The Contractor shall complete the placement of CRCP within 36 hours of beginning removal and shall complete placement prior to any holiday or weekend.

When sending in your sealed bid please state on the front of the envelope that Addendum No. 1 was received.

Sincerely,

DEPARTMENT OF TRANSPORTATION

Mark Peterson
Region Engineer

cc: [M. Brey](#) T. Ondricek J. Steen File